



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. MCS/CH/2024-25/372 dated: 10.03.2025
Issued to :- The Principal
:- Mount Carmel School
:- Sector - 47,B, Chandigarh
Quantity of sample :- Approximate 1200 ml.
Date of Collection :- 13-03-2025
Client reference :- Sample Collected by Laboratory Staff
Packing of sample :- Sample filled in P.P. and Glass Bottle
Source of sample :- from School tap of Mount Carmel School
Sector - 47,B, Chandigarh


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	----	7.68
2	Odour	Agreeable	----	Agreeable
3	Taste	Agreeable	----	Agreeable
4	Turbidity	< 1.0	N.T.U.	0.8
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO ₃)	< 200	mg/l	114
7	Total Hardness (as CaCO ₃)	< 200	mg/l	92
8	Chloride (as Cl)	< 250	mg/l	06
9	Free & Saline Ammonia	NIL	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	162
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received videreceipt No.03/2024-25/238052, dated 12.03.2025, Amount Rs.3300/-

Note: Water is fit for drinking.

Lab No.- MCPHL/25/ 841.....


Dated:- 17.03.2025



Chemist
M.C.P.H. Laboratory
Chandigarh



Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh
Dated :-17.03.2025

Endst No. MCPH/25/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh
For Information Please.


Dr. Parviena John Singh
Principal
Mount Carmel School
Chandigarh


Chemist
M.C.P.H. Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh


MANAGER
MOUNT CARMEL SCHOOL
Sector 47-B, Chandigarh